



MATERIAL LIST - STANDARD UNIT	
ITEM	DESCRIPTION
1	FIBERGLASS MODULAR EQUIPMENT ENCLOSURE - LIGHT GRAY COLOR (LG) ONE 36" DOOR - 3" POLYURETHANE FOAM INSULATION (EXCEPT 1-1/2" ON DOORS) PAINTED WHITE INSIDE - PDI MODEL NO. ME1-120-168
2	GALVANIZED STEEL SKID BASE AND FLOOR - FLOOR PAINTED WITH NON-SKID PAINT - WITH FOUR REMOVEABLE LIFTING EYES - SEE SHT 2
3	BATTERY AND CHARGER EQUIPMENT - (8) BATTERY UNITS, BATTERY RACK AND 48 VOLT 6 AMP BATTERY CHARGER
4	RELAY PANEL - SEE SHT 4
5	AC EQUIPMENT MOUNTING PANEL - 150 AMP MAIN BREAKER PANEL, LIGHT SWITCH, SMOKE DETECTOR AND (2) DUPLEX RECEPTACLE - SEE SHT 8
6	DC PANEL BOARD - SEE SHT 8
7	AIR CONDITIONER - MARVAIR MODEL NO AVP24-ACA-04
8	FOUR FLUORESCENT LIGHTS - TWO TUBE - 4 FOOT TUBES
9	FIRE EXTINGUISHER
10	POSITRON TELELINE ISOLATOR - SUPPLIED BY CUSTOMER

NOTE:

1. MATERIAL:
 - 1) FIBERGLASS LAMINATE 1/4" NOMINAL THICKNESS
 - 2) EXTERIOR UV STABILIZED GELCOAT - 14 MIL NOMINAL THICKNESS COLOR: LIGHT GRAY (LG)
 - 3) INTERIOR: POLYURETHANE FOAM INSULATED - 1-1/2" ON WALLS & 3" ON ROOF - PAINTED WHITE
 - 4) FIRE RETARDANT - DOES NOT SUPPORT COMBUSTION
 - 5) STAINLESS STEEL HARDWARE
2. STANDARDS:
 - 1) CERTIFIED TEST DATA OF ASTM STRUCTURAL STANDARDS AVAILABLE UPON REQUEST

CATALOG NO: ME1-120-1825-L1-LG

FIBERGLASS MODULAR ENCLOSURE
 10 FT WIDE x 10 FT HIGH x 14 FT LONG RELAYS & RECLOSER CONTROLS
 ONE SINGLE DOOR - BRKR BOX, LIGHTS, RECEPTACLES, HEATER - SKID BASE



DRAWN: BB	PAGE 1 OF 10	DATE 10-26-01	DRAWING NO. 1825-R4
--------------	-----------------	------------------	------------------------

FILE REF: